



**TAMIL NADU  
GOVERNMENT GAZETTE**

PUBLISHED BY AUTHORITY

**No.11] CHENNAI WEDNESDAY, MARCH 15,2006**

Panguni 1, Thiruvalluvar Aandu-2037

---

**Part VI --- Section 2**

Notifications of interest to a section of the public issued by  
Heads of Departments, etc.

**NOTIFICATIONS BY HEADS OF DEPARTMENTS, ETC.**

## **TAMIL NADU ELECTRICITY REGULATORY COMMISSION**

### **TAMIL NADU ELECTRICITY DISTRIBUTION (Amendment) CODE**

#### **Notification No. TNERC/DC/8-2/dated 23.02.2006.**

WHEREAS it is considered necessary to issue amending Regulation to the regulation in Tamil Nadu Electricity Distribution Code removing certain difficulties in regard to implementation of the Regulation and the Amending Regulations providing for the above purpose shall be subject to the condition of previous publication and accordingly undergone such previous publications.

NOW, therefore, in exercise of the powers conferred on it by section 181 of the Electricity Act 2003 (Central Act 36 of 2003) and all other powers enabling it in this behalf, the Tamil Nadu Electricity Regulatory Commission hereby specifies the following amending regulations to the Tamil Nadu Electricity Distribution Code issued under Notification No. TNERC/DC/8/1 dated 21.07.2004 and published in Part VI – Section 2 (supplemental) dated 1<sup>st</sup> September 2004.

#### **Amending Regulations**

##### **1. Short title and commencement**

- a. These regulations may be called Tamil Nadu Electricity Distribution (Amending) Code 2006.
- b. These Regulations shall come into force from 23.02.2006.

##### **2. Amendment to Regulation**

The following provision is inserted under clause (b) of sub regulation 14 of Regulation 29 of Tamil Nadu Electricity Distribution Code.

***"Provided that the Chief Executive Officer of the Licensee may approve the point of supply at a place beyond 30 meters from the main gate, if he is satisfied that such place is***

- (a) easily accessible and visible to the officials of the licensee**
- (b) is safe and secure and**
- (c) is not susceptible to mal practice.**

***Also there shall be no compromise on technical grounds, while relaxing the distance criteria.***

**(By order of the Tamil Nadu Electricity Regulatory Commission)**

**R.Balasubramanian  
Secretary**